



1. FOR ELECTRICAL SPECIFICATIONS SEE DWG. 6-1
2. ALL ELECTRICAL CONDUITS TO HAVE A MINIMUM OF 2 #12 WIRES (U.L. STANDARD #42) UNLESS OTHERWISE NOTED.
3. ALL COMMUNICATION CONDUITS SHALL BE 1-1/4" MINIMUM SIZE UNLESS OTHERWISE NOTED.
4. ALL COMMUNICATION WIRING SHALL BE TEFLON INSULATED.
5. WHEN REMOVING OUTLETS CONNECTED TO CIRCUITS OTHER THAN THOSE INDICATED AT THE END OF EACH ROW, THE CONTRACTOR SHALL REMOVE WIRES COMPLETELY BACK TO PANEL.
6. NO SPLICES ARE PERMITTED IN THE UNDERFLOOR CABLE. SPLICES MAY ONLY BE MADE IN THE HEADER DUCT ACCESS PANEL HANDLES.
7. MINIMUM DISTANCE BETWEEN FLOOR MOUNTED OUTLETS AND OTHER FLOOR MOUNTED OUTLETS OR REMOVABLY FILLED CORE HOLES SHALL BE 16". NO CORE HOLES SHALL BE PERMITTED WITHIN 16" OF THE PERIMETER BUILDING WALL EXCEPT FOR THOSE WITHIN THE CONVEYOR LIFT SHAFT.
8. DEVICE PLATES SHALL BE BRUSH STAIN ANODIZED ALUMINUM. DEVICE PLATES FOR TELEPHONE OUTLETS SHALL HAVE A BRUSHED HOLE.
9. ALL FLOOR OUTLETS AND UNDERCORK BOX ASSEMBLIES BEING REMOVED AND NOT RE-USED ARE TO BE RETURNED TO THE ENGINEER.
10. ALL INTERFACES TO BE UPDATED TO REFLECT CHANGES DUE TO THIS CONTRACT.
11. ALL TELEPHONE AND COMMUNICATION WIRING NOT TO BE RE-USED ARE TO BE REMOVED.
12. THE CONTRACTOR SHALL DISCONNECT AND REMOVE ALL ELECTRICAL ITEMS WHICH ARE TO BE REMOVED DUE TO DEMOLITION AS SHOWN ON ARCHITECTURAL DRAWINGS.
13. ALL LIGHTING FIXTURES IN THE AREA OF WORK SHOWN ARE TO BE REMOVED AND ALL ACCESSORIES AND LIGHT FIXTURES TO BE REMOVED.
14. COORDINATE RECEPTACLE CONFIGURATIONS WITH EQUIPMENT SPECIFICATIONS.
15. GROUND EVERY SECOND PEDESTAL IN EVERY OTHER ROW WITH A CONTINUOUS #6 COPPER GROUND WIRE FROM BASE BUILDING STEEL AND ATTACHED TO PEDESTALS WITH A & B KOPFHELD COMPOUND UNDER CLAMPS.
16. FOR THERMOSTAT LOCATION SEE MECHANICAL DRAWINGS
17. FOR EXACT LOCATIONS AND ORIENTATIONS OF POWER AND SIGNAL OUTLETS SEE ARCHITECTURAL DRAWINGS.
18. ALL STROBE ALARM CABLING SHALL BE TEFLON INSULATED AND JACKETED. COLORED FIRE DEPARTMENT RED, LABELED ITS ENTIRE LENGTH, "FIRE ALARM SERVICE" AND APPROVED BY NEW YORK CITY FOR USE IN CLASS "B" FIRE ALARM SYSTEMS.
19. STROBE ALARM CABLING IN PUBLIC AREAS SHALL BE:
- 19.1. SHALL BE RUN IN 3/4" CONDUIT. CONDUIT SHALL BE COLORED FIRE DEPARTMENT RED, LABELED ITS ENTIRE LENGTH "FIRE ALARM SERVICE". CABLING SHALL BE AS SPECIFIED IN NOTE #21.
20. STROBE ALARM CABLING WITHIN TENANT AREAS CAN BE RUN WITHOUT CONDUIT ABOVE HUNG CEILING. CABLING SHALL BE AS SPECIFIED IN NOTE #17.

